

Information:

Drawer: Accounts Payable - Invoices **Vendor Number:** 1087084 **Vendor Name:** Northern Illinois Backflow

Check Details:


Check Number: E0114533 **Check Amount:** \$ 1,308.73 **Check Date:** 6/30/2026

Invoice Details:

Invoice Number: 407280 **Invoice Date:** 4/24/2026 **PO Number:** B0003561
Voucher Number: V0942985

Document Type: AP Invoice

Document Below



Date	Invoice #
4/24/2026	407280

Ship To
Health and Science Center 425 Fawell Blvd Glen Ellyn, IL 60137

Phone #	Fax #	E-mail	Web Site
630-231-1595	630-231-0550	service@nibackflow.com	www.nibackflow.com

Professional Backflow Prevention
Northern Illinois Backflow



1601 Atlantic Drive Suite 101 West Chicago, IL 60185

(630) 231-1595 fax: (630) 231- 0550 www.nibackflow.com

BACKFLOW PREVENTION ASSEMBLY TEST AND CERTIFICATION REPORT

Customer: COLLEGE OF DUPAGE ACCT: _____

Address: 475 FAWCETT City GLEN ELM State IL Zip _____

Manufacturer	<u>FEBLO</u>	Model	<u>860</u>	Serial#	_____
Size	<u>1 1/2"</u>	Type	<u>FLX - ANTI FREEZE</u>	Location	<u>TEC - IN CEILING</u> <u>BY TQ0026</u>

Reduced Pressure Principle Assembly				RP ☒	DCDA ☐
Double Check Value Assembly				DC ☐	RPDA ☐
				PVB ☐	Air Gap ☐
				SVB ☐	AVB ☐
	Check Valve #1	Check Valve #2	Relief Valve	Notes	
Initial Test	Leaked ☐ Closed Tight ☐ Held at _____ PSID	Leaked ☐ Closed Tight ☐ Held at _____ PSID	Did not Open ☐ Opened at _____ PSID		
Repairs	Cleaned ☒ Replaced ☒	Cleaned ☒ Replaced ☒	Cleaned ☒ Replaced ☒		
Details	<u>REBUILT</u>	<u>REBUILT</u>	<u>REBUILT</u>		
Final Test	Closed Tight ☒ Held at <u>6.2</u> PSID	Closed Tight ☒ Held at <u>6.1</u> PSID	Opened at <u>2.2</u> PSID		

Comments

- COMPLETE REBUILD

The above report is certified to be true.

	Date/Time	Tester	Signature	Tester #	Test Kit	Passed	Failed
Initial Test	4/17/26		ICP	XC 2884	MW845	☒	☐
Repairs						☐	☐
Final Test						☐	☐

Marina Mendez <marina@nibackflow.com>

[External] Invoice #407280 Re: Health & Science Center-Glen Ellyn (Repair)

Marina Mendez <marina@nibackflow.com>

Mon, Jun 8, 2026 at 06:27 PM UTC

CC: Northern Illinois Backflow <northernillinoisbackflow@gmail.com>

BCC:

CAUTION: This email originated from outside of COD's system. Do not click links, open attachments, or respond with sensitive information unless you recognize the sender and know the content is safe.

Thank you!

Marina Mendez

Spielman Plumbing, Inc. 630.231.2725 (24 hr emergency)
Northern Illinois Backflow, Inc. 630.231.1595
1601 Atlantic Drive, Suite 101
West Chicago, IL 60185
630.231.2725 (24 Hour Emergency Service)

3 attachments

Scan2026-06-08_132454.pdf

Outlook-upq1fqph.jpg

Outlook-me3xh2qt.jpg